

JOINT LOSS MANAGEMENT COMMITTEE MEETING MINUTES
TOWN OF TROY
Tuesday May 11th, 2021

Selectmen Present: Richard Thackston (NS), Mary Guild (S), Sarah Lashua (NS)
(S-Supervisor, NS-Non-supervisor)

The Meeting was opening at 11:00 AM.

Members of the Public Present: None

Public Comments: None

Old Business: None

New Business:

The committee was not able to inspect the Water/Sewer Department due to scheduling issues.

The committee met at the Samuel E. Paul Community Center at 61 South Street.

Mary Guild supplied each member with a Health and Safety Inspection form for each of the facilities the committee is inspecting today.

The committee toured the Community Center. The building was very neat, clean, and organized. The storage room and basement need emergency exit lights. The basement also needs exit signs. There needs to be a security clasp to hold the basement doors open when a staff member is down there. Any strong winds can cause the doors to slam closed which could be unsafe to someone coming in or out of the basement. The last issue was the AED needs new pads which have already been ordered. The Recreation Director was made aware of these recommendations.


The Recreation Director offered to be a new member on the Joint Loss Management Committee.

The committee next traveled to the Fire Station at 79 Fitzwilliam Road.

The committee was not able to get access to the Fire Station to do the inspection.

Meeting adjourned at 11:33 AM.

Next Meeting: August 11th, 2021, the committee will inspect the Police Department/Ambulance Bay and the Fire Station.



Sarah Lashua
Administrative Assistant
Joint Loss Committee